

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2016 年 11 月 03 日

报出日期: 2016 年 11 月 03 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S162143(青原)	15	4.47	0	含少许异物	25	7.12	2.00	0.07	--	100	>2419.6	0.21	0.05	--	>200.5
S162144(青出)	<5	0.077	0	无	25	7.11	0.80	<0.01	--	0	0	<0.05	<0.02	0.60	0
S162145(荔原)	20	19.6	0	含少许异物	25	7.12	1.76	0.12	--	160	>2419.6	0.82	0.04	--	>200.5
S162146(荔出)	<5	0.128	0	无	25	7.00	0.56	<0.01	--	0	0	<0.05	<0.02	0.19	0
S162147(金原)	25	14.8	0	含少许异物	25	7.08	1.84	0.25	--	96	>2419.6	0.70	0.06	--	>200.5
S162148(金出)	<5	0.116	0	无	25	6.92	0.64	0.02	--	0	0	<0.05	0.02	0.18	0
GB3838-2002（Ⅲ）					≤35	6~9	≤6	≤0.1			≤10000	≤0.3	≤1.0		≤10000
GB5749-2006	≤15	≤1	无异昧	无		6.5~8.5	≤3	≤0.1		≤100	不得检出	≤0.3	≤0.5	≥0.1-0.	不得检出
检验依据	《生活饮用水标准检验法》(GB/ T 5750-2006)							说明							

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制