

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2016 年 11 月 27 日

报出日期: 2016 年 11 月 27 日

单位： 三亚中法供水有限公司

报告日期：2016年11月27日															
项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S162308(青原)	10	2.76	0	含少许异物	25	6.96	1.68	0.08	--	150	>2419.6	0.10	0.02	--	>200.5
S162309(青出)	<5	0.102	0	无	25	6.93	0.72	0.01	--	0	0	<0.05	<0.02	0.53	0
S162310(荔原)	15	15.8	0	含少许异物	25	6.92	1.44	0.13	--	120	2419.6	0.94	0.04	--	>200.5
S162311(荔出)	<5	0.163	0	无	25	6.85	0.56	0.01	--	0	0	<0.05	0.02	0.19	0
S162312(金原)	10	6.89	0	含少许异物	25	6.96	1.36	0.16	--	80	152.3	0.21	0.04	--	30.6
S162313(金出)	<5	0.144	0	无	25	6.89	0.56	0.01	--	0	0	<0.05	<0.02	0.21	0
															</

制表：

校对:

签发:

水质第14表
海南省城镇供水协会制