

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2016 年 11 月 30 日

报出日期: 2016 年 11 月 30 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S162333(青原)	10	2.78	0	含少许异物	25	6.91	1.84	0.05	--	90	>2419.6	0.14	0.02	--	>200.5
S162334(青出)	<5	0.196	0	无	25	6.97	0.80	0.01	--	0	0	<0.05	<0.02	0.60	0
S162335(荔原)	15	12.0	0	含少许异物	25	6.86	1.76	0.05	--	81	>2419.6	0.76	0.03	--	>200.5
S162336(荔出)	<5	0.108	0	无	25	6.82	0.72	0.01	--	0	0	<0.05	<0.02	0.16	0
S162337(金原)	15	6.82	0	含少许异物	25	6.85	1.60	0.06	--	67	686.7	0.16	0.04	--	>200.5
S162338(金出)	<5	0.126	0	无	25	6.87	0.72	0.01	--	0	0	<0.05	0.02	0.15	0
GB3838-2002（Ⅲ）					≤35	6~9	≤6	≤0.1			≤10000	≤0.3	≤1.0		≤10000
GB5749-2006	≤15	≤1	无异昧	无		6.5~8.5	≤3	≤0.1		≤100	不得检出	≤0.3	≤0.5	≥0.1-0.	不得检出
检验依据	《生活饮用水标准检验法》(GB/ T 5750-2006)						说明								

制表：

校对：

签发:

水质第14表
海南省城镇供水协会制