

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 02 月 09 日

报出日期: 2017 年 02 月 09 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S170263(青原)	10	1.24	0	含少许异物	25	7.00	1.60	0.06	--	38	71.5	0.07	0.04	--	65.9
S170264(青出)	<5	0.102	0	无	25	7.08	0.76	0.01	--	0	0	<0.05	<0.02	0.52	0
S170265(荔原)	15	5.15	0	含少许异物	25	7.10	1.44	0.08	--	52	866.4	0.23	0.04	--	88.5
S170266(荔出)	<5	0.101	0	无	25	7.07	0.64	0.01	--	0	0	<0.05	<0.02	0.17	0
S170267(金原)	15	13.2	0	含少许异物	25	7.00	1.52	0.24	--	130	613.1	0.46	0.04	--	59.1
S170268(金出)	<5	0.089	0	无	25	7.15	0.72	0.01	--	0	0	<0.05	<0.02	0.16	0
GB3838-2002（Ⅲ）					≤35	6~9	≤6	≤0.1			≤10000	≤0.3	≤1.0		≤10000
GB5749-2006	≤15	≤1	无异昧	无		6.5~8.5	≤3	≤0.1		≤100	不得检出	≤0.3	≤0.5	≥0.1-0.	不得检出
检验依据	《生活饮用水标准检验法》(GB/ T 5750-2006)						说明								

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制