

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2017 年 05 月 26 日

报出日期: 2017 年 05 月 26 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S171013(青原)	15	9.46	0	含少许异物	25	7.35	2.00	0.21	--	54	1986.3	0.89	0.20	--	129.8
S171014(青出)	<5	0.170	0	无	25	7.47	0.88	0.01	--	0	0	<0.05	0.04	0.50	0
S171015(荔原)	35	7.68	0	含少许异物	25	7.07	2.72	0.13	--	61	1553.1	1.17	0.50	--	118.4
S171016(荔出)	<5	0.138	0	无	25	7.14	0.80	<0.01	--	0	0	<0.05	0.06	0.16	0
S171017(金原)	10	12.4	0	含少许异物	25	7.15	1.84	0.11	--	90	2419.6	0.60	0.15	--	144.5
S171018(金出)	<5	0.106	0	无	25	7.13	0.80	<0.01	--	0	0	<0.05	0.05	0.12	0
GB3838-2002（Ⅲ）					≤35	6~9	≤6	≤0.1			≤10000	≤0.3	≤1.0		≤10000
GB5749-2006	≤15	≤1	无异昧	无		6.5~8.5	≤3	≤0.1		≤100	不得检出	≤0.3	≤0.5	≥0.1-0.	不得检出
检验依据	《生活饮用水标准检验法》(GB/ T 5750-2006)						说明								

制表：

校对:

签发:

水质第14表
海南省城镇供水协会制