

海南省城镇供水企业水质检测 水质常规日检验报告

检测日期: 2016 年 08 月 06 日

报出日期: 2016 年 08 月 06 日

单位： 三亚中法供水有限公司

项目	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
结果	色度	浑浊度	嗅和味	肉眼可见物	水温	pH值	耗氧量	锰	溶锰	菌落总数	总大肠菌群	铁	氨氮	余氯	耐热大肠菌群
样品编号	度	NTU	级		℃	pH	mg/L	mg/L	mg/L	CFU/mL	CFU/100mL	mg/L	mg/L	mg/L	CFU/100mL
S161527(青原)	35	11.7	0	含少许异物	25	7.11	2.88	0.52	--	--	--	0.92	0.95	--	--
S161528(青出)	<5	0.182	0	无	25	7.08	1.22	0.01	--	--	--	<0.05	0.02	0.55	--
S161529(荔原)	25	26	0	含少许异物	25	7.25	2.00	0.20	--	--	--	0.71	0.20	--	--
S161530(荔出)	<5	0.112	0	无	25	7.01	0.88	0.01	--	--	--	<0.05	<0.02	0.17	--
S161531(金原)	30	30.5	0	含少许异物	25	7.08	2.56	0.34	--	--	--	0.91	0.29	--	--
S161532(金出)	<5	0.087	0	无	25	6.96	0.72	0.01	--	--	--	<0.05	0.03	0.18	--
GB3838-2002（Ⅲ）					≤35	6~9	≤6	≤0.1			≤10000	≤0.3	≤1.0		≤10000
GB5749-2006	≤15	≤1	无异味	无		6.5~8.5	≤3	≤0.1		≤100	不得检出	≤0.3	≤0.5	≥0.1-0.	不得检出
检验依据	《生活饮用水标准检验法》(GB/ T 5750-2006)							说明							

制表:

校对:

签发:

水质第14表
海南省城镇供水协会制